

August 24, 2000

Ms. Grisell V. Diaz-Cotto
Emergency and Remedial Response Division
United States Environmental Protection Agency
Region III
290 Broadway, 19th Floor
New York, NY 10007-1866


Re: July 2000 Discharge Monitoring Report
Leachate Treatment Plant, Operable Unit 1
Kin-Buc Landfill Superfund Site

Dear Ms. Diaz-Cotto:

The July 2000 Discharge Monitoring Report (DMR) for the Leachate Treatment Plant of Operable Unit 1, Kin-Buc Landfill Superfund Site, prepared by U.S. Filter Operating Services is attached. We will provide copies of the DMR to Ian Curtis and Susan Dietrick at the NJDEP.

Should you have any questions concerning the DMR or other site items, please contact me or Glenn Grieb at the Kin-Buc site.

Very truly yours,
USFilter Operating Services
On behalf of SCA Services, Inc.,



Dennis J. Duryea, P.E.
Area Manager

DJD\plb

Enclosure

cc: Ian Curtis - NJDEP
Susan Dietrick - NJDEP
Stephen Joyce - SCA
Carl Januszkiewicz - Waste Management
Glenn Grieb - USFOS, Kin-Buc
File



PERMITTEE NAME/ADDRESS

NAME
ADDRESSSCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817FACILITY
LOCATION
ATTN:KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZNATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001			
PERMIT NUMBER			DISCHARGE NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
00	07	01		00	07	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.011592	0.033805	MGD	*****	*****	*****	***		continuous	flow meter
	PERMIT REQUIREMENT	REPORT	ONLY		*****	*****	*****			continuous	flow meter
pH	SAMPLE MEASUREMENT			***	7.29		8.24	S.U.	0	1/week	grab
	PERMIT REQUIREMENT	*****	*****		6.0	*****	9.0		weekly	grab	
PETROLEUM HYDROCARBONS	SAMPLE MEASUREMENT			***	*****	<0.5	<0.5	mg/l	0	2/month	grab
	PERMIT REQUIREMENT	*****	*****		*****	10	15		2/month	grab	
COD	SAMPLE MEASUREMENT	8.79	12.6	kg/day	*****	97	99	mg/l		2/month	comp.
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT	ONLY			2/month	comp.
BOD-5 % REMOVAL	SAMPLE MEASUREMENT			***	>93%			%	0	2/month	calc.
	PERMIT REQUIREMENT	*****	*****		90	*****	*****		2/month	calc.	
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT	0.11	0.15	kg/day	*****	1.1	2.2	mg/l	0	1/week	comp.
	PERMIT REQUIREMENT	REPORT	ONLY		*****	30	45(1)		weekly	comp.	
DISSOLVED OXYGEN	SAMPLE MEASUREMENT			***	7.3			mg/l	0	1/week	grab
	PERMIT REQUIREMENT	*****	*****		4.0 MIN. INSTANT	*****	*****		weekly	grab	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)					TELEPHONE		DATE		
Dennis J. Duryea, P.E. Area Manager							732 572-4743		00 08 24		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MO	DAY
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)									

PERMITTEE NAME/ADDRESS

NAME
ADDRESS

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

FACILITY
LOCATION
ATTN:

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT		001	
PERMIT NUMBER		DISCHARGE NUMBER	
MONITORING PERIOD			
YEAR	MO	DAY	TO
00	07	01	00 07 31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BENZENE	SAMPLE MEASUREMENT	<0.00021	<0.00021	kg/day	*****	<2.3	<2.3	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.009	0.02		*****	57	134			2/month	grab
CHLOROBENZENE	SAMPLE MEASUREMENT	<0.00026	<0.00026	kg/day	*****	<2.8	<2.8	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.022	0.058		*****	142	380			2/month	grab
1,1 DICHLOROETHENE	SAMPLE MEASUREMENT	<0.00026	<0.00026	kg/day	*****	<2.8	<2.8	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.003	0.009		*****	22	59			2/month	grab
ETHYLBENZENE	SAMPLE MEASUREMENT	<0.00026	<0.00026	kg/day	*****	<2.8	<2.8	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.022	0.058		*****	142	380			2/month	grab
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT	<0.00022	<0.00022	kg/day	*****	<3.1	<3.1	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.008	0.025		*****	52	164			2/month	grab
TOLUENE	SAMPLE MEASUREMENT	<0.00040	<0.00040	kg/day	*****	<4.4	<4.4	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.011		*****	28	74			2/month	grab
1,2-TRANSDICHLOROETHYLENE	SAMPLE MEASUREMENT	<0.00023	<0.00023	kg/day	*****	<2.5	<2.5	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.009		*****	25	60			2/month	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		<small>I certify under penalty of law that I have personally examined and am familiar with the information submitted hereon, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 23 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)</small>					TELEPHONE		DATE		
Dennis J. Duryea, P.E. Area Manager							732 572-4743		00 08 24		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS

NAME
ADDRESS


SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

FACILITY
LOCATION
ATTN:

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001			
PERMIT NUMBER			DISCHARGE NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
00	07	01		00	07	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TRICHLOROETHYLENE	SAMPLE MEASUREMENT	<0.00022	<0.00022	kg/day	*****	<2.4	<2.4	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.010		*****	26	69			2/month	grab
VINYL CHLORIDE	SAMPLE MEASUREMENT	<0.00054	<0.00054	kg/day	*****	<4.3	<4.3	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	0.008	0.016		*****	52.8	106			weekly	grab
ACENAPHTHYLENE	SAMPLE MEASUREMENT	<0.000049	<0.000049	kg/day	*****	<0.94	<0.94	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(A)ANTHRACENE	SAMPLE MEASUREMENT	<0.0000	<0.0000	kg/day	*****	<0.89	<0.89	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(A)PYRENE	SAMPLE MEASUREMENT	<0.000047	<0.000047	kg/day	*****	<0.48	<0.48	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(ghi)PERYLENE	SAMPLE MEASUREMENT	<0.000028	<0.000028	kg/day	*****	<0.54	<0.54	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(k)FLUORANTHENE	SAMPLE MEASUREMENT	<0.000048	<0.000048	kg/day	*****	<0.92	<0.92	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)						TELEPHONE		DATE	
Dennis J. Duryea, P.E. Area Manager						732 572-4743		00 08 24			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE		NUMBER		YEAR MO DAY	
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)									

PERMITTEE NAME/ADDRESS

NAME
ADDRESS


FACILITY
LOCATION
ATTN:

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001			
PERMIT NUMBER			DISCHARGE NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
00	07	01		00	07	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IDENO(1,2,3cd) PYRENE	SAMPLE MEASUREMENT	<0.000031	<0.000031	kg/day	*****	<0.59	<0.59	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
PHENANTHRENE	SAMPLE MEASUREMENT	<0.000072	<0.000072	kg/day	*****	<0.57	<0.57	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	5.4(2)			weekly	grab
ALDRIN	SAMPLE MEASUREMENT	<0.0000013	<0.0000013	kg/day	*****	<0.025	<0.025	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.000133	0.00026		*****	0.0875	0.176			monthly	grab
4,4-DDT	SAMPLE MEASUREMENT	<0.000013	<0.000013	kg/day	*****	<0.1	<0.1	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	0.0000578	0.000146		*****	0.38	0.765			weekly	grab
PCB-1242	SAMPLE MEASUREMENT	<0.000038	<0.000038	kg/day	*****	<0.3	<0.3	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
PCB-1248	SAMPLE MEASUREMENT	<0.000038	<0.000038	kg/day	*****	<0.3	<0.3	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
PCB-1254	SAMPLE MEASUREMENT	<0.000038	<0.000038	kg/day	*****	<0.3	<0.3	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)					TELEPHONE		DATE		
Dennis J. Duryea, P.E. Area Manager		 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					732	572-4743	00	08	24
TYPED OR PRINTED							AREA CODE	NUMBER	YEAR	MO	DAY
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)									

PERMITTEE NAME/ADDRESS

NAME
ADDRESS

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

FACILITY
LOCATION
ATTN:

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT PERMIT NUMBER			001 DISCHARGE NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
00	07	01		00	07	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PCB-1260	SAMPLE MEASUREMENT	<0.000038	<0.000038	kg/day	*****	<0.3	<0.3	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab
ARSENIC	SAMPLE MEASUREMENT	<0.0013	<0.0013	kg/day	*****	<10	<10	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.013	0.026		*****	85.8	172			weekly	comp
CADMIUM	SAMPLE MEASUREMENT	<0.00063	<0.00063	kg/day	*****	<5.0	<5.0	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.0073	0.017		*****	48.2	112			weekly	comp
CHROMIUM	SAMPLE MEASUREMENT	<0.0013	<0.0013	kg/day	*****	<10	<10	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.030	0.060		*****	198	396			weekly	comp
COPPER	SAMPLE MEASUREMENT	0.00018	0.00025	kg/day	*****	1.3	2.0	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	10			weekly	comp
LEAD	SAMPLE MEASUREMENT	<0.00046	<0.00046	kg/day	*****	<5.0	<5.0	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	10			weekly	comp
NICKEL	SAMPLE MEASUREMENT	<0.0051	<0.0051	kg/day	*****	<40	<40	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.140	0.281		*****	924	1850			weekly	comp
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)					TELEPHONE		DATE		
Dennis J. Duryea, P.E. Area Manager							732 572-4743		00 08 24		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT					AREA CODE	NUMBER	YEAR	MO	DAY
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)									

PERMITTEE NAME/ADDRESS

NAME
ADDRESS

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

FACILITY
LOCATION
ATTN:

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001			
PERMIT NUMBER			DISCHARGE NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
00	07	01		00	07	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE	
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS				
ZINC	SAMPLE MEASUREMENT	0.0024	0.0053	kg/day	*****	17.9	41.8	ug/L	0	1/week	comp	
	PERMIT REQUIREMENT	0.177	0.356		*****	1170	2350			weekly	comp	
CYANIDE	SAMPLE MEASUREMENT	<0.0013	<0.0013	kg/day	*****	<10	<10	ug/L	0	1/week	comp	
	PERMIT REQUIREMENT	0.002	0.004		*****	13.2	28.4			weekly	comp	
ALUMINUM	SAMPLE MEASUREMENT	0.0094	0.013	kg/day	*****	81	123	ug/L	0	1/week	comp	
	PERMIT REQUIREMENT	1.40	2.81		*****	9240	18500			weekly	comp	
IRON	SAMPLE MEASUREMENT	0.026	0.081	kg/day	*****	198	637	ug/L	0	1/week	comp	
	PERMIT REQUIREMENT	80.6	162		*****	532000	1070000			weekly	comp	
ACUTE TOXICITY, (LC50)	SAMPLE MEASUREMENT			***		*****	*****	%				
	PERMIT REQUIREMENT	*****	*****		50(3)	*****	*****			see permit	equivalent	
	SAMPLE MEASUREMENT			***		*****	*****			*****	*****	
	PERMIT REQUIREMENT					*****	*****			*****	*****	
	SAMPLE MEASUREMENT			***		*****	*****			*****	*****	
	PERMIT REQUIREMENT	*****	*****			*****	*****			*****	*****	
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)						TELEPHONE		DATE		
Dennis J. Duryea, P.E. Area Manager								732 572-4743		00 08 24		
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						AREA CODE	NUMBER	YEAR	MO	DAY
COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS		(REFERENCE ALL ATTACHMENTS HERE)										

NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATER QUALITY

MONITORING REPORT - TRANSMITTAL SHEET

NJPDDES NO.

*						
---	--	--	--	--	--	--

*NJ Permit Equivalent

REPORTING PERIOD

M	o.	Y	r.	M	o.	Y	r.
0	7	0	0	0	7	0	0

PERMITTEE: Name: SCA Services, Inc.
 Address: 383 Meadow Road
 Edison, New Jersey 08817

FACILITY: Name: Kin-Buc Landfill
 Address: 383 Meadow Road
 Edison, New Jersey 08817
 Telephone: 732-572-4743

FORMS ATTACHED (Indicate Quantity ___ of Each)

Operating Exceptions

SLUDGE REPORT-SANITARY

___ T-VWX-007 ___ T-VWX-008 ___ T-VWX-009
___ EPA Form 3320-1

DYE TESTING

YES NO
___ X

TEMPORARY BYPASSING

___ X

SLUDGE REPORT-INDUSTRIAL

___ T-VWX-010A ___ T-VWX-010B

DISINFECTION INTERRUPTION

___ X

WASTEWATER REPORTS

___ T-VWX-011 ___ T-VWX-012 ___ T-VWX-013

MONITORING MALFUNCTIONS

___ X

UNITS OF OPERATION

___ X

GROUNDWATER REPORTS

___ T-VWX-015(A,B) ___ T-VWX-016 ___ T-VWX-017
___ ELECTRONIC SUBMISSION

OTHER

___ X

NPDES DISCHARGE MONITORING

X EPA Form 3320-1

(Detail any "Yes" on reverse side in appropriate space.)

NOTE: The "Hours Attended at Plant" on the reverse of this sheet must also be completed.

AUTHENTICATION I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

LICENSED OPERATOR

PRINCIPAL EXECUTIVE OFFICER OR
DULY AUTHORIZED REPRESENTATIVE

Name (Printed) Dennis J. Duryea
Grade & Registry No. N-4, 0014528
Signature *Dennis J. Duryea*

Name (Printed) Dennis J. Duryea
Title (Printed) Plant Operations Manager
Signature *Dennis J. Duryea*

Date August 24, 2000

[illegible]

MONTH | 0 | 7 | YEAR | 0 | 0

Others

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
0	0	8	0	8	8	8	0	0	8	8	8	8	0	0	
0	0	16	0	16	16	16	0	0	16	16	16	16	16	0	0
17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	
8	8	8	8	8	0	0	8	8	8	8	8	0	0	8	
16	16	16	16	16	0	0	16	16	16	16	16	0	0	16	